


8








- AVAIL probability that system is available
- POFOD Probability Of Failure On Demand
 irregular use: fire alarm
- ROCOF Rate of OCcurrence Of Failure
 regular use: coffee machine
 - per time unit (week) or usage (per 1000 cups)
- MTTF Mean Time To Failure


 long transactions (editor)
 1/ROCOF

Software Engineering













				A sasantah ilitas
Identified hazard	H a z a r d probability	Accident severity	Estimated risk	Acceptability
1.Insulin overdose computation	Medium	High	High	Intolerable
2. Insulin underdose computation	Medium	Low	Low	Acceptable
 Failure of hardware monitoring system 	Medium	Medium	Low	ALARP
4. Power failure	High	Low	Low	Acceptable
5. Machine incorrectly fitted	High	High	High	Intolerable
 Machine breaks in patient 	Low	High	Medium	ALARP
7. Machine causes infection	Medium	Medium	Medium	ALARP
 Electrical interference 	Low	High	Medium	ALARP
9. Allergic reaction	Low	Low	Low	Acceptable













Active failure (Human error)


20




















32

Process [13.2, 15.4]

Standardized process

- Precise specification
 - Assign Safety Integrity Level (SIL)
- Safety reviews (hazard monitoring)
- Diverse verification (inspection, model checking, test, proof)
- Version management
- Quality culture (process is accepted)

Software Engineering

31

Process

- Documentation
 Auditable
- Independent safety regulator
 - process is dependable
 - do we have the right process
 - process is followed
 - are we doing the process right

Software Engineering