

Useful results

Laplace transform table

Table 1: Basic Laplace transforms

$f(t)$	$F(s)$	$f(t)$	$F(s)$
unit impulse $\delta(t)$	1	$\sinh(bt)$	$\frac{b}{s^2 - b^2}$
unit step $1(t)$	$\frac{1}{s}$	$\cosh(bt)$	$\frac{s}{s^2 - b^2}$
t	$\frac{1}{s^2}$	$\frac{1}{2b}t \sin(bt)$	$\frac{s}{(s^2 + b^2)^2}$
t^n	$\frac{n!}{s^{n+1}}$	$t \cos(bt)$	$\frac{s^2 - b^2}{(s^2 + b^2)^2}$
e^{-at}	$\frac{1}{s+a}$	$\frac{\cos(bt) - \cos(at)}{a^2 - b^2}; (a^2 \neq b^2)$	$\frac{s}{(s^2 + a^2)(s^2 + b^2)}$
$\frac{1}{(n-1)!} t^{n-1} e^{-at}; (n = 1, 2, 3\dots)$	$\frac{1}{(s+a)^n}$	$\frac{\sin(at) + at \cos(at)}{2a}$	$\frac{s^2}{(s^2 + a^2)^2}$
$\sin(bt)$	$\frac{b}{s^2 + b^2}$		
$\cos(bt)$	$\frac{s}{s^2 + b^2}$		
$e^{-at} \sin(bt)$	$\frac{b}{(s+a)^2 + b^2}$		
$e^{-at} \cos(bt)$	$\frac{s+a}{(s+a)^2 + b^2}$		

Table 2: Properties of Laplace Transforms

$\mathcal{L}[af(t)] = aF(s)$	$\mathcal{L}[tf(t)] = -\frac{dF(s)}{ds}$
$\mathcal{L}[f_1(t) \pm f_2(t)] = F_1(s) \pm F_2(s)$	$\mathcal{L}[t^2 f(t)] = \frac{d^2}{ds^2} F(s)$
$\mathcal{L}\left[\frac{d}{dt} f(t)\right] = sF(s) - f(0)$	$\mathcal{L}[t^n f(t)] = (-1)^n \frac{d^n}{ds^n} F(s); n = 1, 2, 3, \dots$
$\mathcal{L}\left[\frac{d^2}{dt^2} f(t)\right] = s^2 F(s) - sf(0) - f'(0)$	$\mathcal{L}\left[f\left(\frac{t}{a}\right)\right] = aF(as)$
$\mathcal{L}\left[\int f(t) dt\right] = \frac{F(s)}{s} + \frac{1}{s} \left[\int f(t) dt\right] _{t=0}$	$\mathcal{L}\left[\int_0^t f_1(t-\tau) f_2(\tau) d\tau\right] = F_1(s) F_2(s)$
$\mathcal{L}[e^{-at} f(t)] = F(s+a)$	

Matrix exponential

$$e^{At} \triangleq \mathcal{L}^{-1}\{(sI - A)^{-1}\}$$

Open-loop and sensitivity functions

$$G_o(s) = G(s)F_y(s), \quad S(s) = \frac{1}{1 + G_o(s)}, \quad T(s) = 1 - S(s)$$

State-space forms and transfer function relations

- State-space form and transfer function

$$\begin{aligned} \dot{x} &= Ax + Bu \\ y &= Cx + Du \end{aligned} \Rightarrow \boxed{G(s) = C(sI - A)^{-1}B + D}$$

•

$$\mathcal{S} = [B \ AB \ \cdots \ A^{n-1}B] \quad \mathcal{O} = \begin{bmatrix} C \\ CA \\ \vdots \\ CA^{n-1} \end{bmatrix}$$

- LTI system with transfer function

$$\boxed{G(s) = \frac{b_0 s^n + b_1 s^{n-1} + \cdots + b_n}{s^n + a_1 s^{n-1} + \cdots + a_n}}$$

i) Observable canonical form

$$\begin{aligned} \begin{bmatrix} \dot{x}_1 \\ \dot{x}_2 \\ \dot{x}_3 \\ \vdots \\ \dot{x}_n \end{bmatrix} &= \begin{bmatrix} -a_1 & 1 & 0 & \cdots & 0 \\ -a_2 & 0 & 1 & \cdots & 0 \\ -a_3 & 0 & 0 & \cdots & 0 \\ \vdots & \vdots & \vdots & \vdots & \vdots \\ -a_n & 0 & 0 & \cdots & 0 \end{bmatrix} \begin{bmatrix} x_1 \\ x_2 \\ x_3 \\ \vdots \\ x_n \end{bmatrix} + \begin{bmatrix} b_1 - a_1 b_0 \\ b_2 - a_2 b_0 \\ b_3 - a_3 b_0 \\ \vdots \\ b_n - a_n b_0 \end{bmatrix} u \\ y &= [1 \ 0 \ \cdots \ 0] \begin{bmatrix} x_1 \\ x_2 \\ \vdots \\ x_n \end{bmatrix} + b_0 u \end{aligned}$$

ii) Controllable canonical form

$$\begin{aligned} \begin{bmatrix} \dot{x}_1 \\ \dot{x}_2 \\ \dot{x}_3 \\ \vdots \\ \dot{x}_n \end{bmatrix} &= \begin{bmatrix} -a_1 & -a_2 & -a_3 & \cdots & -a_n \\ 1 & 0 & 0 & \cdots & 0 \\ 0 & 1 & 0 & \cdots & 0 \\ \vdots & 0 & \vdots & \vdots & \vdots \\ 0 & 0 & 0 & \cdots & 0 \end{bmatrix} \begin{bmatrix} x_1 \\ x_2 \\ x_3 \\ \vdots \\ x_n \end{bmatrix} + \begin{bmatrix} 1 \\ 0 \\ 0 \\ \vdots \\ 0 \end{bmatrix} u \\ y &= [b_1 - a_1 b_0 \ b_2 - a_2 b_0 \ \cdots \ b_n - a_n b_0] \begin{bmatrix} x_1 \\ x_2 \\ \vdots \\ x_n \end{bmatrix} + b_0 u \end{aligned}$$

- Solution to state-space equation

$$\dot{x}(t) = Ax(t) + Bu(t), \quad x(0) = x_0$$

can be written as

$$\boxed{x(t) = e^{At}x_0 + \int_0^t e^{A\tau}Bu(t-\tau)d\tau}$$

- Observer system

$$\boxed{\dot{\hat{x}} = A\hat{x} + Bu + K(y - C\hat{x})}$$

Feedback control structures

General linear feedback form:

$$\boxed{U(s) = F_r(s)R(s) - F_y(s)Y(s)}$$

We can write the following control structures in Laplace form.

- PID controller:

$$F_y(s) = F_r(s) = F(s) = K_p + \frac{K_i}{s} + K_d s,$$

where $K_p, K_i, K_d \geq 0$

- Lead-lag controller:

$$F_y(s) = F_r(s) = F(s) = K \left(\frac{\tau_D s + 1}{\beta \tau_D s + 1} \right) \left(\frac{\tau_I s + 1}{\tau_I s + \gamma} \right),$$

where $K, \tau_D, \tau_I > 0$ and $0 \leq \beta, \gamma < 1$

- State-feedback controller with observer:

$$\begin{aligned} F_r(s) &= (1 - L(sI - A + KC + BL)^{-1}B) \ell_0 \\ F_y(s) &= L(sI - A + KC + BL)^{-1}K \end{aligned}$$

Discrete-time state-space forms

A continuous time system with zero-order-hold input signal and sample period T can be written in discrete-time as:

$$\boxed{\begin{aligned} x(k+1) &= Fx(k) + Gu(k) \\ y(k) &= Hx(k) \end{aligned}}$$

where

$$F = e^{AT}$$

$$G = \int_{\tau=0}^T e^{A\tau} d\tau B = [\text{if } A^{-1} \text{ exists}] = A^{-1}(e^{AT} - I)B$$

$$H = C$$